BIODEX MEDICAL SYSTEMS, INC. 20 Ramsey Road Shirley, New York 11967-4704

D.O.T. SPECIFICATION 7A, TYPE A PACKAGING TEST RECORD

DATE: DECEMBER 22, 2003

PACKAGE IDENTIFICATION: DOUBLE UNIT DOSE PIG SHIPPING SYSTEM,

MODEL #001-787

Testing was performed at: Biodex Medical Systems, Inc., 20 Ramsey Road, Shirley, NY 11967-4704 USA

| PACKAGE | DESCRIPTION | SIGNED OFF BY |
|--|---|---------------|
| Outer Case: | | |
| manufacturer of case | Zero Plastic | C5 |
| construction material | rotation molded polyethylene | |
| wall strength, lb test | N/A | |
| dimensions, inches | 11.75 x 11.75 x 12.5 (h) | |
| closure | hinged lid, 2 clasps | |
| internal cushioning | high density polyurethane foam | |
| Lead Insert Shielding Package: | | |
| material | cast lead in a contoured shape to supply | |
| | appropriate shielding to inner pig - open | |
| | top and bottom on lead - holds 2 pigs | |
| insert support | metal plate to hold and position lead | |
| Unit Dose Pig: | | |
| material | lead encased in plastic shell with integral | |
| | liner | |
| | Lead: body .5" | |
| | top 1.44" | |
| | bottom 1.2" | |
| closure | plastic screw threads between top and | |
| | bottom sections, single turn twist lock | |
| cushioning | N/A | |
| dimensions, " | 10.2" long x 2.4" diameter | 1 |
| Lead Shielding Combined: | bottom: 1.2" | |
| | top: 1.44" | |
| | sides: varies depending on | |
| | location from .56 to 1.8" | |
| Weight: | | - |
| outer shield and case | 40.1 lbs | |
| unit dose pig #1 | 8.9 lbs | |
| unit dose pig #2 | 8.9 lbs | |
| Total Weight | 58 lbs | |
| Primary Container Unit Dose Pig: | | |
| syringe | Two 5 cc syringes used in individual pigs | |
| nominal volume ml | 2.4 ml and 2.6 ml | |
| closure | needle and needle cover or luer cap | |
| content simulation | water, colored | |
| absorbent materials | absorbent sheet (001-771) | |
| Examination of test sample before tests: | | |
| Describe: | | |
| defects | none | |
| distortions | none | |
| deterioration | none | |
| printing imperfections | none | |

| TESTS | NOTES | SIGNED OFF BY |
|--|---|---------------|
| TEST RECORD: | Perform tests in order and attach a photographic record | |
| WATER SPRAY TEST: 49 CFR 173.465 (b) (must be performed before remaining tests) | Two (2) cases were sprayed. Case 1 and 2 at the same time. A nozzle was placed on each side of the cases and water sprayed for more than one (1) hour at a rate greater than two (2) inches per hour. | <u></u> |
| | A hose was connected to the pipe for a shower head was run and then split into four (4) hoses – each with a nozzle on the end. The hose nozzles were on the four(4) sides of the cases. | |
| Spray Package: from 1 or 4 sides rate approx. 2 inches / hour time at least 1 hour | spray from 4 simultaneously greater than 2 inches / hour sprayed for more than 1 hour | |
| Describe Results: | The water spray did not affect the plastic shipping container. | |
| | The case had some water in it. | |
| | NOTE: If the package was sprayed from 4 sides simultaneously, the other tests may begin up to 2 hrs. after the water is turned off. | |
| | If the spray is from 1 direction on each side sequentially, the compression test must begin within 1 hour. | |

| TESTS | NOTES | SIGNED OFF BY |
|--|---|------------------------|
| FREE DROP TEST: | | |
| onto flat concrete surface | | |
| Drop Test one foot onto 8 corners 49 CFR 173.465 (c) (2) (CASE 2) | dropped on all 8 corners | <u>CS</u> |
| Describe Results: | pigs are OK, small scratches on case corners syringes did not lose any material into caps absorbent material is dry | <u></u> |
| Drop Test four feet for maximum damage: 49 CFR 173.465 (c) (1) (CASE 2) | plastic zip tie case closed drop onto latches for maximum damage | |
| Describe Results: | case stayed closed – case is scratched pigs are OK syringes are OK – no leakage into needle caps | <u>CS</u> |
| Drop Test 30 feet: 49 CFR 173.466 (a) (1) (CASE 1) | case taken to top of building and dropped 30 feet onto concrete apron | <u>c</u> 5 |
| Describe Results: | case hit on bottom near edge case stayed closed pigs stayed together lead was bent tapped pigs forward to remove one pig can lift out bottom section plastic is cracked syringe is OK second pig bottom is stuck in case tapped to move threads in top and bottom are cracked. syringe is OK – needle cap is dry absorbent material was dry. some water from outer case Spray Test leaked onto ground | <u> </u> |
| PENETRATION TEST: 49 CFR 173.466 (a) (2) and IATA 10.6.3.5.2 (CASE 2) using 1.25 in. diameter bar with hemispherical end weighing 13.2 lbs. Drop from 67 inches: strike point clock time | Determined the top was the weakest location so dropped the rod onto the top of the case hit off center near rib N/A | <u>cs</u> |
| Describe Results: | the bar penetrated the top plastic lid of case case stayed together pigs are OK syringes are OK - no leakage into needle caps PASSES TEST | <u>05</u> <u>cs</u> |

| TESTS | NOTES | SIGNED OFF BY |
|-----------------------------|---|---------------|
| COMPRESSION TEST: | NOTES | SIGNED OFF DI |
| 49 CFR 173.465 (d) (CASE 2) | | |
| performed December 1999 | | |
| 24 hours compression: | | |
| weight in lbs. | greater than 600 pounds | |
| clock time - start | N/A | <u> </u> |
| clock time - finish | timer, 24 hours | |
| | NOTE: | |
| | Compression test was performed by placing a | |
| | sheet of plywood with lead bricks onto the top of | |
| | the plastic case. The heaviest system weighs 55.2 | |
| | lbs. The stacking test is (2 lb./in ² x vertical | |
| | projected area of package, which would be 277 | |
| | lbs. or 5x's the weight of the package) which is | |
| | 276 lbs. We used over 600 lbs. of lead bricks on | |
| | top of the shipping system. | |
| | There was no damage or effect to the plastic | _ |
| | container. None of the inner shields were | CS |
| Describe Results: | damaged during this test. | |
| | | |
| | | |
| ACCEPTANCE CRITERIA: | Damage to the packaging may not cause loss or | |
| | dispersal of simulated contents. | |
| | 2.7 | |
| | 2. Damage to the packaging may not cause an | |
| | increase in calculated surface radiation exposure. | |
| | 3. The test record must be complete and accurate, | |
| | and the photographic record attached. | |

| T . | C | 1 1 |
|--------|---------|--------|
| Acto | perform | ed by: |
| 1 0010 | | CUMIV. |

Initials ______

Kenneth Paladino

Initials \(\frac{\Q}{}

Date: January 22, 2004

Note:

Additional tests were performed by Dayton T. Brown. These tests were for compliance to:

Temperature Test IATA 10.6.2.4.1.4 and 49CFR 178.608

Pressure Test IATA 10.6.1.3; IATA 5.0.2.9 and 49CFR 173.410(c)

Vibration Test IATA 5.0.4.3 (also 49CFR 178.608 and 173.24 (a) (a) (5))

These tests are available from Biodex upon request.

Rev: August 14, 2018